CURRENT YEAR FIRE ALARM INCIDENT LOG

Note: this does not include drills.

Note 2: Does not include unreported individual room/suite smoke detector activations.

Year	Date	Incident	Location	Cause	Injuries	Death	Property Value
2024	2/17/24	CO Detector	Full System	Fire Alarm Panel Malfunction	0	0	\$0
	2/28/24	Local Smoke Detector	Bellamy Hall Suite 206	Scent Infuser set off alarm	0	0	\$0
	4/24/24	CO Detector	Bellamy Hall Mechanical Room	Utica Fire Dept. identified off-gassing from floor cleaning machine	0	0	\$0
	5/10/24	Smoke Detector	Butterfield Hall	Blow Dryer	0	0	\$0